

*If you are using a printed copy of this procedure, and not the on-screen version, then you **MUST** make sure the dates at the bottom of the printed copy and the on-screen version match. The on-screen version of the Collider-Accelerator Department Procedure is the Official Version. Hard copies of all signed, official, C-A Operating Procedures are kept on file in the C-A ESHQ Training Office, Bldg. 911A.*

C-A OPERATIONS PROCEDURES MANUAL

ATTACHMENT

1.5.c Safety Information for Testing or Diagnosing of Sub-Range B Energized Circuits

Text Pages 2

C-A OPM Procedures in which this Attachment is used.		
1.5		

Hand Processed Changes

<u>HPC No.</u>	<u>Date</u>	<u>Page Nos.</u>	<u>Initials</u>
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

Approved: *Signature on File* _____
 Collider-Accelerator Department Chairman Date

P. Cirnigliaro

Safety Information for Testing or Diagnosing of Sub-range B Energized Circuits

1. Identify and locate:
 - Power sources and shutoff devices
 - Emergency telephones
2. Establish work area:
 - Notify affected personnel
 - Cordon off work area
3. Remove Conductive Apparel
4. Review NFPA 70E for proper Personal Protective Equipment.
5. Wear safety glasses
6. Measurement technique:
 - Ground one terminal of tester
 - Measure to ground
 - Use one hand at a time
7. De-energize all sources and stored energy devices
 - Verify
8. Lock-out and Tag-out all sources of energy:
 - Verify
9. Re-energize Only sources < 132 Volts RMS AC or 300 Volts DC to ground
10. Use “WIGGY” or similar tester to verify
11. Stop work and report to supervisor in any warning conditions exist
12. Perform Testing
13. STOP if terminal cannot be reached or is not in sight
14. On completion of work:
 - Remove all materials and equipment
 - Close enclosures
 - Remove barriers
 - Notify affected personnel
 - Remove locks and tags
 - Re-energize equipment
 - Report to supervisor